

Emission Test Certificate

Monday, October 25th, 2011

Supplier: Aquatherm (6F 443 West Botany St, Rockdale, NSW 2216)

Sample Description: Aquatherm Fusiotherm Potable Water Pipe System

Date Tested: October 2011 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

<p>Green Building Council of Australia Green Star Office Interiors IEQ-11</p>	<p>Aquatherm Fusiotherm Potable Water Pipe System</p>
<p>Total Volatile Organic Compound Emission Rate limit <math><0.5\text{mg}/\text{m}^2/\text{hr}</math></p>	<p>Total Volatile Organic Compound Emission Rate: <math><0.008\text{ mg}/\text{m}^2/\text{hr}</math> (24 hours)</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV110924